

**DISTRICT WATER TESTING LABORATORY, FEROZPUR**

Department of water supply and sanitation, zira gate, circular road, Ferozpur  
dwtlfzr@gmail.com

To,

Suman Lata  
Wisdom International Public School, Kabarwachha Road, Mudki Ferozepur-142060


No.: DWTL/FZR/2324/00014 Dated : 03/05/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 181 Dated: 02/05/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/05/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Ferozpur

D/A : Test Report



Authorized Signatory  
For, District Water Testing Laboratory,  
Ferozpur

**WISDOM INTERNATIONAL PUBLIC SCHOOL**

  
**DIRECTOR**  
Principal  
Wisdom International Public School  
MUDKI-142060

**DISTRICT WATER TESTING LABORATORY, FEROZPUR**  
Department of water supply and sanitation, zira gate, circular road, Ferozpur  
dwtfzr@gmail.com



**TEST REPORT**

Name & Address of Customer : <b>Suman Lata</b> Wisdom International Public School, Kabarwachha Road, Mudki Ferozepur-142060		Customer Reference No.	No : 181 Dated : 02/05/2023			
		Sample Submitted by	Money			
		Date of Sample Receipt	02/05/2023			
		Analysis Starting Date	02/05/2023			
		Analysis completion Date	03/05/2023			
Discipline : Chemical Testing		Group: Water				
ULR No.:	TC10375230000052F	Sample Type :	Water			
Test Report No.:	DWTL/FZR/2324/00014	Date of Issue :	03/05/2023			
Registration no.:	DWTL/FZR/REG2324/00101	Condition of Sample :	Sealed			
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Wisdom International Public School, Kabarwachha Road, Mudki Ferozepur- 142060 / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Not Mentioned	District :	Ferozpur			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.35	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	220	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	120	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	100	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	32	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	4.8	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method

*Suman Lata* Principal  
Wisdom International Public School  
MUDKI-142060

WISDOM INTERNATIONAL PUBLIC SCHOOL  
*P. Pachre*  
DIRECTOR



**DISTRICT WATER TESTING LABORATORY, FEROZPUR**  
 Department of water supply and sanitation, zira gate, circular road, Ferozpur  
 dwtlfr@gmail.com



11	Chloride	20	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

*Manju Vasis*

**Mrs. Manju  
 Quality Manager  
 Authorized Signatory  
 For, District Water Testing Laboratory,  
 Ferozpur**

----- End of the Test Report -----

WISDOM INTERNATIONAL PUBLIC SCHOOL

*K. Pachre*  
 DIRECTOR

*Suman Lata* Principal  
 Wisdom International Public School  
 MUDKI-1420